Micromonitoring

John M. H. Barton, Joseph Kamalesh and Roger Jacobsen

In the 20 y period since the advent of the area–velocity flow monitor, the development of hydraulic models has greatly improved the planning and design of two of the three solutions to overflows and basement backups which sometimes result when excessive stormwater enters the sanitary sewer system. The three general solutions for overflows and basement backups are: prevention of stormwater from entering the system (inflow–infiltration, I/I, reduction), storage facilities for excess stormwater, and increased conveyance capacity to the downstream treatment plant. Of these three, only the design and planning of I/I reduction has not substantially benefited from hydraulic modeling improvements. This is unfortunate as it is the greenest, and often the least costly, of the solutions. Micromonitoring is a new tool which greatly improves the design and planning of such I/I removal as a solution.

Computing power on the desk of an engineer today was only available through universities and government research institutions twenty years ago. The advent of geographic information systems (GIS) provided hydraulic modelers with a wealth of ready and useful digital data. Combined, these advances transformed hydraulic models from merely trunk sewer models to all pipe models with base flows generated from water use records at every house.

However, the ability to compute the generation of base flow in every pipe did nothing to supply the detailed information about the storm flow generated by every pipe. The more detailed models improved the planning and design of storage and conveyance solutions downstream of the flow meters, but remained little more than estimates (or guesses) of the distribution of those flows upstream of the flow monitors. The real benefit of the increased detail in the models upstream of the flow monitors was accurate stage–storage and stage–discharge curves upstream in those areas during sewer surcharge.

As hydraulic models have become more detailed, engineers have increased the amount of flow monitoring data considered necessary to build a model from which reasonable predictions of future performance can be made. It was not uncommon in the 1990s for engineers to model the conversion of rainfall to sewer flow using unit hydrographs developed from the flow monitoring results of a single storm. In these models, unit hydrographs were applied to design storms of various magnitudes to obtain a prediction of the peak flow rates and volumes which would then be used as the basis of design for sewer improvements. This one-storm approach has steadily been supplanted in the past twenty years by an increasing demand for flow monitoring data-sets collected for longer periods of time. Seasonal changes and back-to-back storms critically affect the volume of stormwater entering the sanitary sewer, and therefore longer flow records provide a better basis for the design of storage facilities.

The conveyance solution implemented by building larger pipes similarly benefits from the more detailed models. One storm can be replaced by several storms for analysis, which in turn can be replaced by monitoring the entire wet season (Kurz, 2003; Kurz et al., 2003). Then the recognition that stochastic models required independent data from both the dry season and the wet season pushed the flow monitoring period up to a full year. Today the modeling engineer is not truly satisfied unless they have flow data for several years, from both before and after any modifications.

Storage and conveyance solutions which have greatly benefited from modeling improvements are considered to be structural improvement solutions. It takes several years to implement and execute structural solutions. Every step of the process, from the recognition of the need until the breaking of the bottle of champagne can add more time, cost and complexity. Large scale system-wide or regional flow monitoring programs often take several years from mobilization to close-out. The subsequent data processing, review and reporting can continue for more months. Engineering analysis and modeling, the development of alternatives, costing, and selection all take additional project time. When the dirt settles on a constructed structural solution, it will have been a long time from the day the municipality first decided to collect flow monitoring data (McMullin et al., 2007).

Reduction of I/I, which is a green solution, can often result in obvious and focused work items such as downspout removal and catchbasin disconnection, although the results may be uncertain. Ideally, these defects are found early in the process and it can be determined from the regional flow monitoring data if there is any impact from their removal, but traditionally the process is very uncertain. The success or failure of attempts to find the actual I/I sources do not depend on the length of the data period recorded or the level

of detail in the hydraulic model, but upon identification of the source. This does not depend on the modeling accuracy, but on the spatial resolution of the monitoring data. Thus improvements in I/I reduction result from increasing the number of discrete data points (spatial resolution), not from longer data sets or more frequent data points (Stevens, 1993). Micromonitoring therefore solves the two big problems associated with greater spatial resolution: low flows and high costs.

8.1 What is a Micromonitor?

Before describing how the micromonitor improves on measuring low flows without high costs for data collection, a brief description of the device itself is necessary. A micromonitor is a combination of a standard area-velocity (AV) sensor (such as an ISCO 2150 or an ADS FlowShark) with a smooth custom made weir downstream of the sensor. Figure 8.1 shows the micromonitor using an ISCO 2150 sensor.

Figure 8.1 A typical micromonitor installed in a low flow pipe.

The primary calculation of flow is from the continuity equation using the level and velocity calculated by the AV sensor. In normal or low slope

pipes, the micromonitor has a rating curve that can be used at flows $\sim < 20$ gpm (1.3 L/s) (see Figure 8.2). In steeper pipes the higher velocity results in an overestimation of the flow rate. The primary purpose of the weir in the micromonitor is not the application of the rating curve, but the prevention of debris accumulation at low flows.

Figure 8.2 In flat pipes the micromonitoring weir rating curve can be used at flow rates below 15 gpm (0.95 L/s).

8.2 Micromonitoring Works in Low Flows

Greater spatial resolution is achieved by moving the flow monitors further up into the system. Shifting away from the deep smooth flow of the trunk sewers, where scattergraphs look nice and daily flow patterns are reproducible, the micromonitors are placed at points in the system where each flush of a toilet can be observed.

Conventional flow monitoring often suffers from debris fouling and limitations of the equipment when it is applied to discrete areas such as streets with fifteen houses or pipe segments serving a single office building. Yet we know this is where the flow must be collected, and the micromonitor is the tool to do so.

The change in flow patterns in the immediate vicinity of the band and probe can result in sanitary sewer debris obstructing the probe. In general, the lower the flow the more disruptive the probe is to the flow pattern. The blunt face of the probe offers the perfect opportunity for debris to be caught (see Figure 8.3). The manufacturers of the flow monitoring equipment curve the edges of the probe to minimize the obstruction, but when the flow is 0.25 in. (6.35 mm) deep, the debris will catch on any obstruction.

Figure 8.3 Greater spatial resolution for flow monitoring requires the monitoring of lower flows, where debris is a significant problem.

The micromonitoring weir maintains a minimum depth of about 0.7 in. (17.8 mm). This depth allows the debris to remain suspended and so to move around the AV sensor. The leading edge of the weir has a very flat slope. This

allows the debris to be channeled up and over the weir by smooth flow lines (see Figure 8.4).

Figure 8.4 Smooth flow lines and greater minimum depth with a micromonitor reduce the number of debris obstructions.

The AV sensor (continuous wave technology) contains two piezo-electric crystals in the blunt face. One of these crystals will emit the ultrasonic signal, which bounces off the particles moving in the water. The return signal from the particles is picked up by the other crystal. The change in the frequency of the signal provides a measurement of the average velocity of the fluid.

In order for this process to work, both the crystals must be under water, or the signal is unreliable. Some manufacturers will not even take a velocity measurement when the flow is <1 in. (25.4 mm) deep. The micromonitoring weir maintains a 1 in. (25.4 mm) flow at flow rates >2 gpm (0.13 L/s) (see Figure 8.5).

Figure 8.5 The AV probe must be covered to obtain a reliable velocity reading.

8.3 Micromonitoring Higher Spatial Resolution at Lower Cost

Higher spatial resolution simply means more monitoring points. Lower costs result from a reduced duration and reduced criticality of data.

The micromonitoring for I/I measures flow from smaller basins for much shorter times. Micromonitoring can narrow the search for the individual I/I sources to a single street and from a single storm. Figure 8.6 shows data for six days from the monitoring of two similar areas. Both areas are relatively small encompassing 20 houses to 40 houses. It does not take years of data and multiple storms to determine which of these two streets has the I/I sources. We could monitor for additional storms, and would expect some variability in response, but we would still expect results to show that the pipe in the lower graph has no I/I and does not need further investigation, while the pipe in the upper graph would continue to show a significant response storm by storm. Micromonitoring provides results from just a single storm, bringing us back to the one storm approach of twenty years ago with a more usable definition.

Figure 8.6 Two adjacent micromonitors, a one storm indication of the presence or absence of I/I.

This one storm approach to monitoring does not result in the exact black box function which converts a rainfall driving force to an I/I response, but it does provide a yes–no, street by street answer to the presence of I/I. Rainfall variability is substantially eliminated when comparing I/I from two micromonitors in close proximity. Distribution of rainfall is not an issue for an area >20 acre (8 ha) (Huff and Angel, 1992).

Micromonitoring requires a single storm with measurable I/I at the downstream regional meter. This significantly reduces the risk associated with loss of data. When the relationship between the rainfall and I/I is built from a statistical relationship developed from many storm events, the loss of a single large event can significantly change the resulting predictions (Barton, 2006). When upstream and downstream flow monitors must be subtracted to estimate the contribution of I/I from the basin in between, it is vital that both meters work properly. It is a source of great error when there are missing values during significant storms.

The frustration that modelers face from missing data rolls downhill to the next project undertaken by the flow monitoring provider. The contract language is tighter, more compulsory and the penalties are more severe. The selection process for the best site is more involved. Information on this detailed site selection process is found in Barton (2004) and in Barton et al. (2004). These requirements come with a cost. As the flow monitoring provider is taught to fear the loss of data, more money is spent to preserve it.

It is easier to find a site for micromonitoring because the relative magnitude of results, the yes–no of I/I, does not require the same rigorous flow conditions. If the site gives bad data, the micromonitor can be moved on the next iteration. Obviously if a crew finds serious problems with a site when they attempt to install the micromonitor, they should move upstream or downstream to find a better site and need not wait for the bad data to be confirmed. Micromonitoring follows the initial results of the regional monitors to focus the investigation in high I/I areas (see Figure 8.7).

Figure 8.7 Micromonitors provide the spatial resolution in basins with high I/I rates.

The one storm approach is the biggest factor in the lowering of costs. Additional and substantial cost savings can also be obtained because the micromonitors can be installed from the surface without entering the man-hole, as shown in Figure 8.8. Prior to installation the micromonitor is calibrated in a calibration tube above the surface, as shown in Figure 8.9. One storm instead of one year, reduced program requirements and reduced installation expenses all add up to lower costs per site. Lower costs per site allow for a significant increase in spatial resolution and that improves the search for I/I.

Figure 8.8 The micromonitor can be installed from the surface without confined space entry (CSE).

Figure 8.9 The micromonitor can be calibrated in a tube prior to installation.

8.4 Case Study in CCWA

The first application of micromonitoring to isolate I/I was in Clayton County, Georgia in February 2011 (Barton and Kamalesh, 2012). This project was part of an extensive I/I study conducted by the Clayton County Water Authority (CWAA) on one of its largest sewersheds. The traditional regional flow monitoring began in 2010 with 118 flow monitors. The majority of these were placed in branches entering the main trunk sewers. Based on the results of the regional flow monitoring, I/I rates were assigned to each basin.

Late in 2010, the CCWA began to undertake investigations for the I/I sources in the basins with the highest reported I/I rates. These investigations included primarily the following tools: smoke testing, manhole inspections, and closed circuit television (CCTV). In each case the consulting engineer assigned to investigate the basin had a limited quantity of these tools available and had to exercise good judgment to determine where they should be employed. Whenever problems were located in the field, CCWA undertook the necessary repairs. After investigating several basins applying the assigned quantities, Stantec discussed a new approach with CCWA.

Stantec had just successfully monitored very small flows in sewers in Seattle, Washington using a new device, the micromonitor. The Seattle project was looking at the effect of the redirection of stormwater away from small

combined sewers. The sewers in question were attached to only ten or so houses. The micromonitor was deployed to measure the very low flows from those areas. During the project, it became obvious that the micromonitor could be a powerful tool in the investigation of I/I sources. So Stantec discussed this new approach with CCWA engineering staff, to determine if a basin could be micromonitored first so that the limited investigation quantities could be more carefully applied. CCWA decided to conduct a pilot study and the first I/I project to use micromonitoring was under way.

The first basin to be micromonitored was 071, shown in Figure 8.10. Basin 071 had a modest, but clear, response to rainfall in the spring of 2010. This basin has six tributary branches along a trunk sewer which follows a creek bed. Suspicion naturally centered on the trunk sewer along the creek bed, as wet riparian soils are ideal I/I sources. Stantec proposed micromonitoring the six tributary areas to rule some of them out from further investigation. The search could then center on the trunk sewer and areas with a high I/I response during micromonitoring.

With CCWA's approval the six micromonitors and one regional flow monitor were installed early in February 2011 as shown in Figure 8.10. As often seems to happen with any flow monitoring project, the dry spell began just as the monitors went into place. But just before the end of the 30 d period, the project area received 0.96 in. (24.4 mm) rainfall.

Figure 8.10 Micromonitoring plan for basin 071.

Figure 8.11 shows the results of two of the micromonitors from the storm event which occurred on 2011 02 28. These show an example of the I/I and no I/I results. The majority of the inflow in the basin was from upstream of micromonitor 6 (MM-06), though there was some infiltration upstream of micromonitor 4 (MM-04). The decision was made to smoke test the entire basin, but the other I/I investigations were focused upstream of MM-04 and MM-06. Figure 8.11 shows the approximate volumetric I/I during the storm for each basin.

Figure 8.11 Micromonitoring in basin 071; volumes are I/I from the 2011 02 28 storm.

As an interesting finish to the pilot study, the CCTV contractor found what was presumed to be the source of the direct inflow upstream of MM-06. When the CCTV camera could not pass a root ball in the line, the contractor proceeded to insert a root cutter to clear the line. The root cutter cleared the roots but found and cut a gas main in the process (Figure 8.12). The area was evacuated and emergency repairs were carried out. This was not a typical day in the field, but certainly a bit more exciting! Several other defects were found upstream of MM-06 but they did not seem to be significant contributors of I/I. The section of pipe that was broken has now been replaced with a new PVC pipe. Additional post-replacement monitoring of this section is recommended to confirm that the location of the gas line intrusion was the likely source of I/I. Wet weather CCTV would have provided definitive information about the sources (Barton and Kamalesh, 2011).

Figure 8.12 Gas line through the sanitary sewer upstream of MM-06.

CCWA determined that the better spatial resolution provided by the micromonitoring was well worth the cost as it focused on the use of other conventional sanitary sewer evaluation survey (SSES) investigations only in problem areas and not basin wide. CCWA has decided to micromonitor four more basins since that time.

8.5 Conclusions

Micromonitoring provides the higher spatial resolution needed to make I/I elimination a more certain endeavor for the engineer. However, micromonitoring is not in itself a replacement for the long term regional meters installed in the project. Conveyance and storage options still need the long term datasets to provide an accurate basis for design. Micromonitoring is just the newest item in the I/I toolbox. It precedes the other traditional SSES investigations such as manhole inspections, smoke testing and CCTV. The objective of micromonitoring prior to SSES investigations is to determine which individual pipe segments need to be investigated for defects, thus eliminating areas which do not have any problems. It hence cost effectively focuses the investigation on a fairly concentrated section of the project area. Thus

micromonitoring refines the search for I/I sources by chasing them down to the smallest reach of pipe. It has been proven that money spent on micromonitoring has a very good return on investment as the costs of expansive SSES investigations are reduced.

References

- Barton, J. (2004). Flow Monitoring Site Selection for Large Modeling Applications. OWEA, 2004.
- Barton, J., S. Donovan and D. Abadie. 2004. "Practical Flow Monitoring for Large Modeling Applications." *Journal of Water Management Modeling* R220-14. doi: 10.14796/JWMM.R220-14.
- Barton, J. (2006). "Strategies of I/I Removal and Performance Indicators for Pipeline Rehabilitation," Presentation to Korean Society of Water and Wastewater, Dankook University, July 6, 2006.
- Barton, J. and J. Kamalesh (2011). "Low-impact Inflow/infiltration Investigation," Public Works, Oct 2011, pp 42–47.
- Barton, J. and J. Kamalesh (2012). "Ohio Engineering Team Develops New Tool for Low Impact I/I Investigations." Buckeye Bulletin, OWEA 82: 269–73.
- Huff, F. and J. Angel (1992). "Rainfall Frequency Atlas of the Midwest," Midwestern Climate Center, Bulletin 71, MCC 92-03.
- Kurz, G. (2003). "Rainfall Induced I/I (RDII) Analysis Methodology," Buried Asset Management Institute (BAMI) Pilot Project Proposal
- Kurz, G., G. Ballard, M. Burgett and J. Smith (2003). "A Proposal for Industry-Wide Standardization of I/I Calculations," Proceedings of the WEFTEC 03: 76th Annual Water Environment Federation Annual Technical Exhibition and Conference.
- McMullin, J, A. Lukas and S. Heinz (2007). "Milwaukee MAS I/I Reduction Cost-Effectiveness," Proceedings of the North American Society for Trenchless Technology 2007 No-Dig Conference, San Diego, CA April 16–19, 2007.
- Stevens, P. (1993). "Basin Size is the Most Effective Variable an I/I Engineer Can Control," Proceedings of the Water Environment Federation 66th Conference, October 1993.